

**DoP no.: 10-SAT-100/2014**

1. Unique Product Identification Codes: **JB-YY; JB-Y(St)Y** fire alarm cables
2. Description of the product type: **1x2x0,8; 2x2x0,8; 3x2x0,8; 4x2x0,8; 6x2x0,8; 10x2x0,8; 1x2x1,0; 2x2x1,0; 1x2x1,5; 2x2x1,5**
3. Intended Use: Fire Alarm Cables.
For fire detection and control systems. With properties limiting the generation and spread of fire.
4. Contact address: **SAT-ELIT 2000 KFT.** H-2081 Piliscsaba, Vár utca 20.
cable@sat-ELIT2000.hu
5. System or systems of assessment and verification of constancy of performance of the construction product:
System 4
6. Notified laboratory code: ----
7. Declared Performance:

Important Criteria	Performance	Standards
Reaction to fire	F _{ca}	EN 60332-1-2
Dangerous substances	None	

8. The performance of the product identified in point 1 is in conformity with the declared performances in point 7. According to decree 305/2011/EU this declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Piliscsaba, 24 May 2017.

Behalf of the manufacturer:

Udvarhelyi Gábor
Quality Assurance Manager